



- ① CURB STOP VALVE AND SERVICE BOX
- ② TYPE K COPPER TUBING
- ③ GATE VALVE
- ④ FLARED COPPER TO IRON COUPLING OR DENVER WATER APPROVED EQUAL
- ⑤ METER
- ⑥ CHECK VALVE (NOT REQD IF BACKFLOW DEVICE IS INSTALLED)
- ⑦ FLANGE LOC PAC COUPLING
- ⑧ 48" CONC MH
- ⑨ CONC MH BASE BEAMS USED ONLY FOR TRAFFIC AREAS

# DENVER WATER

1800 West 12th Avenue • Denver, Colorado 80204  
Phone (303) 628-6000 • Telecopier No. (303) 628-6851



## OUTSIDE SETTING FOR 1 1/2" & 2" IRRIGATION METER IN VAULT

Scale: NONE Date: AUGUST 1995

Drawn: C.B.B. Tr:      Ck:     

Approved: *[Signature]* Dr. 127 No. 35